



Welcome back, **schweig** | [Staff Panel](#) | [My Preference](#) | [Log Out](#)

- [Tickets](#)
- [Knowledge Base](#)
- [Directory](#)
- [My Account](#)
- [FAQs](#)

- [Open \(20\)](#)
- [My Tickets \(5\)](#)
- [Overdue \(2\)](#)
- [Closed Tickets](#)
- [New Ticket](#)

Ticket #912809 _

[Edit Ticket](#)

Status:	open	Name:	Robert Hower
Priority:	Low	Email:	hower@umich.edu (134)
Department:	Management	Phone:	
Create Date:	01/07/2015 8:44 am	Source:	Email

Subject: Light sticks on the wet benches

Assigned Staff:	Dennis Schweiger	Help Topic:	N/A
Last Response:	02/26/2015 2:55 pm	IP Address:	141.213.7.201
Due Date:		Last Message:	01/07/2015 8:44 am

Ticket is assigned to Dennis Schweiger

Action: ▼ **Priority:** ▼

[Internal Notes \(1\)](#)

Fri, Jan 9 2015 8:14am - posted by Dennis Schweiger

Ticket Assigned to Dennis Schweiger

Assign to self

[Ticket Thread](#)

Wed, Jan 7 2015 8:44am

Topic: Infrastructure

Location: Clean Room

All of the wet benches in 1440 are on the scheduler and have associated fees. Only 2 are interlocked. The rest need at least a light stick that can be easily seen with the camera's to ensure that the users are

reserving the benches.

Ideally these would be expandable to include a signal for "alone in the lab" or "<4 people in the lab" when we get the new LSS.

Rob

Thu, Feb 26 2015 2:55pm - Dennis Schweiger

Lights have currently been added to all of the benches in the 1440 space, and the Access system is programmed to turn them on at a body count of <4 people.

We may want to rethink this turn-on level as the lamps could be on for hours on end, and like everything, the users will get used to a flashing lamp....

Response Posted Successfully

[Post Reply](#)

[Post Internal Note](#)

[Dept. Transfer](#)

[Re Assign Ticket](#)

Canned Response: Append

Append Signature: None My signature

Ticket Status: Close on Reply

Copyright © 2006-2015 osTicket.com. All Rights Reserved.